

VAISHAL PATLIPUTRA DUGDH UTPADAK SAHKARI SANGH LIMITED

PATNA DAIRY PROJECT

Feeder Balancing Dairy Complex, Phulwarisharif, Patna-801505

Ph: 0612- 2251622, 2252553, 2252542

Email Id.- vpmu.pur@gmail.com

VPDUSS-SOP-8.5.1.2-01.F02

PDP:PUR:FBD: 5416

DATE- 25.08.2025

Dear Sir,

We are interested in purchase of Two (02) no. of Exhaust System for Surbhi Section. If party interested to do work may submit the quotation in sealed envelope latest by 10.09.2025.

Details scope of work & technical specification for the Exhaust System for Surbhi Section are as follows-

1. Supply, Installation & Testing of SS 304 hoods along with baffle filters for Sudha Surbhi vat - ----- 02 nos.
2. Supply, Installation & testing of Centrifuge Exhaust fan having heavy duty MS powder coated, dynamically balanced impeller with double skin PUFF panel SS planum suitable for wall/ceiling mounting, 4000CFM @ 75mm WC static pressure ----- 02 nos.
3. Supply, Installation & testing of site fabricated SS 304 duct, 24 guage SS 304 sheet (0.63mm) ----- 40 Sqm.
4. Supply & erection of SS supporting structure for inside the building ----- 30kg
5. Supply, Installation & testing of powder panel with DOL starter, starter panel for 02 nos exhaust fan ----- 01 no.

Thanking You

Yours faithfully


Dy. Manager(MM)